

POOL / SPA SUBMITTAL REQUIREMENTS

As required by Bureau Veritas North America, Inc.

ALL INFORMATION MUST BE FILLED IN, CHECKED OR MARKED N/A

- Application
- Local Municipal Approval
- Site Plan of pool/spa location showing any overhead lines
- 1 copy of manufacturer specifications and plans (must be at site)

The following items, views and details shall appear on all plans:

- 1. Location of pool must be so that any overhead service entrance cables are 22.5' from the water level in any direction. If installing a diving board or platform a distance of 14.5' must be maintained.
- 2. If in-ground pool, consideration for any underground utilities should be taken. No non-pool related underground wire within 5' of pool wall unless in approved conduit.
- 3. Pool wiring:
 - a. Feed wires and branch circuit wires need to be installed in conduit. NM (romex) allowed indoors only in residential.
 - b. Conduit must be of the following type: RMC, IMC, LFNMC, RNC
- 4. Bonding:
 - a. All metal parts of structure & equipment must be bonded
 - b. Exception: isolated parts < 4" in any dimension and do not penetrate the pool structure < 1"
 - c. Bonding with a 8 AWG or larger conductor
- 5. Grounding:
 - a. Grounding conductors must be insulated
 - b. No splices in conductors must land in terminals
- 6. Lighting:
 - a. Underwater Wet-Niche:
 - 1. Installed where top of fixture lens is not less than 18" below water line
 - 2. Bonded and secured to shell requiring a tool for fixture removal
 - 3. Low voltage lines from UL listed transformer separate from line voltage
 - 4. Over 15 V must be GFCI protected
 - 5. Connections in Wet-Niche must be potted
 - 6. Metal parts in contact with pool water need to be corrosion-resistant
 - 7. Junction boxes for pools must be UL listed for use
 - b. Dry-Niche:
 - 1. Provided with means for drainage of water
 - 2. One equipment-grounding conductor for each conduit entry
 - c. No-Niche:
 - 1. UL listed for use
 - 2. Installed in forming shells connected for each conduit bracket

7. **Receptacles and Equipment Locations:**
 a. Receptacles for circulation and sanitation systems of pools shall be permitted to be located between 5' and 10' from pool wall and be a single rec. GFCI protected with ground and be of a locking type.
 b. Permanently installed pools require a receptacle at least 10' but no more than 20' from pool wall
 c. All exterior receptacles within 20' of pool walls need to be GFCI protected
 d. An accessible disconnecting means for all equipment except lighting shall be located within site of equipment and not less than 5' from pool wall
8. **Lighting Outlets:**
 a. Existing lights less than 5' from pool wall and at least 5' above the water level need to be GFCI protected
 b. New installation above the pool or within 5' of pool wall need installed at least 12' above the water line
 c. Indoors lights with a totally enclosed fixture or identified for use can be 7'6" above the water if GFCI protected
 d. Switches other than ones UL listed need to be at least 5' from pool wall
9. **Entrapment protection:**
 a. All pool and spa suction outlets shall conform to ANSI/ASME A112.19.8M or be a drain grate of at least 12" X 12" or larger or an approved channel drain

SPAS AND HOT TUBS

10. **Spas and hot tubs follow same rules as pools except for:**
 a. Factory assembled units can connect to power source with a 15" cord to a GFIC outlet
 b. Bond all metal parts within 5' of spa or hot tub
 c. GFCI protection to spa or hot tub not required if pumps, heaters, lights and other electrical equipment is protected by self contained GFCI UL listed from factory
 d. No wall switches or appliances within 5' of hot tub or spa
 e. Indoor locations: Light fixtures permitted less than 7' 6" over spa or hot tub if GFCI protected, enclosed with glass or plastic lens, no exposed metal parts and listed for damp locations.

REQUIRED BARRIERS

11. **Barriers are designed to provide protection against potential drowning by restricting access to swimming pools, hot tubs and spas:**
 a. The barrier must be at least 48" to the top above the finish grade
 b. Openings in barrier shall not allow a 4" diameter sphere to pass through
 c. Access gates for pedestrians shall have a self locking device and be of a self closing type
 d. The release mechanism for the gate must be at least 54" from the bottom of the gate or be located at least 3" below the pool side of the top of the gate
 e. If a wall of a dwelling serves as part of the barrier all doors that directly access the pool need to be equipped with an audible alarm
 f. Where an above ground pool serves as the barrier the ladder or steps need to be capable of being locked, secured or removed to prevent access

g. Barriers shall be constructed and located away from structures, equipment or similar objects to prevent them from being used to climb on or over the barriers

h. Barrier exceptions – hot tubs or spas with a safety cover complying with ASTM F 1346 shall be exempt from these provisions.

12.

Decks:

a. Decks built 30" high above grade require guards

b. Plans for deck need to be submitted for approval at time of permit application

c. Deck footing must be a minimum of 36" deep

d. Access to decks around pools must meet above barrier requirements

e. Decks cannot cantilever on above ground pool walls without proof from the manufacturer that the pool is capable of supporting the deck

13.

Portable or storable pools:

a. Cord connected pumps shall have a double insulated cord and ground that grounds all internal non-accessible metal parts

b. Electrical equipment needs protected by GFCI circuit

c. Lights for storable pools need to be UL listed with no exposed metal parts

I have read and understand the above requirements for the installation of swimming pools and/or spas. By signing this document I agree to install my pool/spa in accordance with the Pennsylvania Uniform Construction Code Law.

Print Name

Signature

Date

THIS COMPLETED FORM MUST BE TURNED IN WITH PLANS

July 18, 2006

Permit No. _____

Bureau Veritas North America, Inc.

PERMIT APPLICATION

For questions or to submit your paperwork, please contact the office nearest you
(locations attached)

Township or Borough: _____ Date: _____

Work Site Address: _____
(street) (city) (state) (zip)

Owner/Applicant: _____ Phone: _____

Mailing Address: _____
(street) (city) (state) (zip)

Contractor: _____ Phone: _____

Contractor Address: _____
(street) (city) (state) (zip)

TYPE OF WORK (Please check either "Residential" or "Commercial" below and provide all information requested)

Residential Project: Description _____ Cost \$ _____

New Bldg. Square Footage All Floors: _____ (not including garage)

Finished Basement Square Footage (if applicable) _____

Office Use Only

Use Group _____ Construction Type _____ Code Used _____

Commercial Project: Description _____ Cost \$ _____

New Building Existing Building New Bldg. Square Footage All Floors: _____

Use Group _____ Construction Type _____ Occupancy Load _____ Code Used _____

I hereby certify that the proposed work is authorized by the owner of record and that I am or have been authorized to make this application as his/her authorized agent and we agree to conform to all applicable laws of this jurisdiction.

Print Name _____

Signature _____ Date _____

OFFICE USE ONLY

Building Plan Review Date: _____

Approved

Not Approved

Plan Reviewer: _____

Permit Fee: \$ _____

OVER

RIDGWAY BOROUGH MUNICIPAL PRIOR APPROVALS

(To ensure that all local ordinances are complied with, this form must be completed by the applicant and signed by a Municipal Official prior to the issuance of a building permit by Bureau Veritas North America, Inc.)

Applicant/Property Owner: _____ Phone: _____

Mailing Address: _____

Contractor: _____ Phone: _____

Address: _____

Project Cost: \$ _____

Please check one below:

Residential Project: Description _____ Size: _____

Commercial Project: Description _____ Size: _____

Work Site Address: _____

I hereby certify that the proposed work is authorized by the owner of record and that I have been authorized to make this application as his authorized agent and we agree to conform to all applicable laws of this jurisdiction.

Signature: _____ Date: _____

APPLICANT MUST HAVE BOROUGH COMPLETE THE FOLLOWING:

Site Located Within Flood Plain? _____ Zoning Type _____

Type of Sewage: _____ (Approval Attached) Not Applicable

Type of Water: _____ (Approval Attached) Not Applicable

Road Occupancy Permit: _____ (Approval Attached) Not Applicable

Stormwater Management: _____ (Approval Attached) Not Applicable

I hereby certify that this application is in compliance with all relevant ordinances of Ridgway Borough and therefore eligible for Municipal approval.

Date Approved/Issued: _____

Borough Officer/Secretary: _____



BUREAU
VERITAS

Bureau Veritas Office Locations - Pennsylvania

Western Pennsylvania	Eastern Pennsylvania
Armstrong Office	Broomall Office
204 Butler Road, Suite 3	790A Parkway Drive
Kittanning, PA 16201	Broomall, PA 19008
P: 724.548.1414	P: 877.392.9445
F: 724.548.1403	F: 877.392.9444
Brookville Office	Pocono Office
1514 Route 28	5510 Memorial Drive
Brookville, PA 15825	Tobyhanna, PA 18466
P: 814.849.2448	P: 570.894.2801
F: 814.849.0825	F: 570.894.2986
Huntingdon Office	Wyoming Office
10773 William Penn Highway, Suite D	184 Keiserville Road
Huntingdon, PA 16652	Tunkhannock, PA 18657
P: 814.643.3480	P: 570.836.7196
F: 814.643.3766	F: 570.836.5967
Mifflin Office	
821 Electric Avenue, Suite C	
Lewistown, PA 17044	
P: 717.242.0992	
F: 717.242.4391	
Somerset Office	
451 Stoystown Road, Suite 105B	
Somerset, PA 15501	
P: 814.701.2181	
F: 814.701.2182	